

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 17-51-00148
Name of Facility: Jim Bailey Middle School
Address: 4110 Bauer Road
City, Zip: Pensacola 32506

**Correct By: None
Re-Inspection Date: None**

Type: Public Schools
Owner: Escambia County School Board
Person In Charge: Tara Palasciano Phone: (850) 492-6136
PIC Email: TPalasciano@ecsdfi.us

Inspection Information

Purpose: Routine
Inspection Date: 9/30/2022
Begin Time: 09:50 AM
End Time: 10:30 AM

Additional Information

FEMALES 572
MALES 598
CENSUS 1170

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION		
<u>IN</u> 1. School Site	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>NA</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
BUILDING CONST/MAINT.	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
<u>IN</u> 4. Construction	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 5. Maintenance & Repair	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>IN</u> 6. Lighting Standards	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 8. Natural Ventilation	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 9. Mechanical Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
SANITARY FACILITIES	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
<u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

No violations at the time of inspection. See note/warning below.

Note: Student boy restroom near cafeteria - loose faucet at handwash sink. Repair as needed.

Warning: Drinking fountain just past room 609 - dirty fountain pan and bottle filler spout. Thoroughly clean to remove pink biofilm buildup from fountain pan and bottle filler spout and maintain clean condition.

Inspector to recheck these items at the next routine inspection.

TPalasciano@ecsdfl.us
JJackson5@ecsdfl.us
ejones2@ecsdfl.us
Jhiggins@ecsdfl.us

Email Address(es): TPalasciano@ecsdfl.us;
JJackson5@ecsdfl.us;
ejones2@ecsdfl.us;
Jhiggins@ecsdfl.us;

Violations Comments

No Violation Comments Available

Inspection Conducted By: Christie Gillenwater (027985)
Inspector Contact Number: Work: (850) 595-6700 ex. 2006
Print Client Name: Tara Palasciano
Date: 9/30/2022

Inspector Signature:

Handwritten signature of Christie Gillenwater.

Client Signature:

Handwritten signature of Tara Palasciano.